



**BID REQUEST
ADDENDUM NUMBER TWO (2)**

DATE: October 16, 2019

RE: BID NO. 2020-03 – ANNUAL CHEMICAL

OWNER: CITY OF EDINBURG

TO: ALL PROPOSERS, HOLDERS OF SPECIFICATIONS, AND ALL
ALL INTERESTED PARTIES TO THE CITY OF EDINBURG

All Addenda issued in respect to this project shall be considered official changes to the original bid documents and shall become a part of the contract documents.

SPECIFICATIONS ADDENDUM ITEM AS SPECIFIED BELOW:

GENERAL DESCRIPTION

It shall be understood and agreed that the duration of this contract will be for thirty-six (36) months and that the price stated shall remain firm for the duration of the contract. The price quote shall be for two (2) new chlorine dioxide generator units, each with an emergency backup unit, or by having spare parts easily available at each location within the City. The units shall be located at two (2) raw water intake sites:

- West Tower Pump Station #1
- West Treatment Plant

AS SEEN ON PAGE 6 OF THE SERVICE TO PROVIDE CHLORINE DIOXIDE - SPECIFICATIONS

5. The bidder's SODIUM CHLORITE solution must be approved and registered with the ENVIRONMENTAL PROTECTION AGENCY (EPA): be acceptable to the TEXAS COMMISSION ON ENVIRONMENTAL QUALITY (TCEQ) and conform to American National Standards Institute/National Sanitation Foundation (ANSI/NSF) Standard 60 for use in public potable water systems. Bidder's equipment must meet (ANSI/NSF) Standard 61 for use in public potable water systems as well.

AS SEEN ON PAGE 6 OF THE SERVICE TO PROVIDE CHLORINE DIOXIDE - SPECIFICATIONS





7. Bidder shall supply, install, and maintain two (2) new heavy duty, double walled, sun resistant (black in color) bulk chemical storage tank for receiving, storing, and dispensing sodium chlorite on site. Tank capacity shall be five-thousand (5,000) gallon capacity. Bidder shall provide signage and warning of hazards in the storage and generation area. Bulk tank shall be equipment with an ultrasonic level monitoring indicator so as to monitor level inside tank at tank location. Bidder will be responsible for the proper operation and setup of said level indicator.


AS SEEN ON PAGE 7 OF THE SERVICE TO PROVIDE CHLORINE DIOXIDE – SPECIFICATIONS

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED BELOW AND RETURN TO MS. LORENA FUENTES, PURCHASING AGENT VIA EMAIL AT lfuentes@cityofedinburg.com. PLEASE INCLUDE THIS FORM IN YOUR BID PROPOSAL.

NAME: _____ TITLE: _____

COMPANY: _____

If you have any questions or require additional information, do not hesitate to contact Ms. Lorena Fuentes, Purchasing Agent at (956) 388-1895.



Lorena Fuentes, Purchasing Agent

