



EDINBURG FIRE MARSHAL'S OFFICE



P.O. Box 1079 • 212 West McIntyre Street
Edinburg, Texas 78539
Office: (956) 383-7691 ♦ Fax: (956) 289-1853

FIRE INSPECTION REPORT

ADDRESS:		DATE:	
OCCUPANT:		PHONE:	
TYPE OF OCCUPANCY:			
TYPE OF INSPECTION: <input type="checkbox"/> ANNUAL <input type="checkbox"/> RE-INSPECTION <input type="checkbox"/> COMPLAINT <input type="checkbox"/> OTHER:			

OUTSIDE FACILITY

- Need to post address: 6" in front / 3" in rear.
- Does not meet fire code: fire department accessibility / F.D.C. visibility / fire lanes.
- Hydrants: obstructed / need repair.
- Need to remove accumulation of: boxes / trash / rubbish.
- Electrical meter box needs: # of suite / repair.
- Unauthorized burning without a permit.
- L.P.G. being used when natural gas is available.

INSIDE FACILITY

- Permits: not visible / expired.
- Need to maintain good housekeeping.
- Combustibles stored under wooden stairs.
- MSDS: not on site / needs to be updated.
- Fire wall/partition needs to be: installed/repared.
- Stairs / ramps: need correct size / rails.
- Ceiling tiles: missing / need to be replaced.
- Congestion of materials / aisle obstructions.
- No approved trash cans.
- Chemically treated dust mops and oily rags not stored in metal containers with lids.
- Boiler permit due: _____.
- Water heater/dryer: not vented properly / lint build up / discharged incorrectly / needs repair.
- Dust covered motors, need to be cleaned.
- Electrical breaker panel: access obstructed / _____ needs labels / needs repair.
- Missing safety covers: junction box / light switches / outlets.
- Light fixtures: close to stock/improperly installed.
- Permanent wiring: not in conduit / needs repair / need to remove extension cord(s) / not to code.
- Interior decorations exceed 20% wall coverage.
- Fuel shut off, obstructed / needs to be labeled.

EXITS

- Exits: need to install ___ / does not swing outward / needs repair / locked during business hours.
- Exit access / discharge: blocked, needs to be clear at all times.
- Exit signs: install 6" red letter sign / needs repair / not visible.
- Emergency lighting: needs to install/ needs repair.
- Travel distance to exit does not meet fire code.

EXTINGUISHERS

- Extinguisher: incorrect Class / needs recharging / needs to be inspected by a licensed company.
- Extinguisher access and visibility: needs label / blocked.
- No fire extinguishers in building; need to install.
- Travel distance does not meet fire code.

KITCHEN HOODS / SUPPRESSION SYSTEM

- Does not meet: NFPA 96 / 17A / UL 300.
- Hood / vent / suppression system: need to clean / needs inspection by a licensed co. / needs repair.
- Nozzles: position / missing caps / needs repair.
- Piping: location / incorrect size / needs repair.
- Storage tank: location / incorrect type / needs inspection by a licensed company.
- Pull station(s): obstructed / needs repair.
- Filters: need cleaning / missing / incorrect type.
- Electrical wiring: defective / needs repair.
- Open flames need 18" distance from combustibles.
- Hood does not have 6" overhang.
- Cooking appliances: not protected / improperly placed under nozzles / accumulation of grease.
- Need to install Class "K" fire extinguisher.

ALARMS

- Required as per NFPA 72.
- Alarm panel: obstructed / needs repair / needs to be inspected / needs a smoke detector over panel.
- Smoke detector(s): located incorrectly / needs battery replacement / required by HB #2046.
- Heat detector(s): located incorrectly/needs repair.
- Pull station(s): obstructed / needs repair / need tamper cover.
- Audible and visual: obstructed / needs repair.
- Special operations: elevator / HVAC / other.
- Zone maps required.

AUTOMATIC SPRINKLER SYSTEM

- Required as per NFPA 13 (D/R).
- Sprinkler riser: needs inspection / obstructed.
- Valves need repair.
- Piping need repair.
- Sprinkler head(s): obstructed / incorrect type / needs 18" clearance / needs repair.
- Sprinkler head storage cabinet: obstructed / incorrect # of heads in storage / missing wrench.
- Inspector test valve: location / size / condition.
- Need to replace water gong with horn & strobe.
- Fire pump: needs repair / needs to be tested.
- Hose cabinets: obstructed / need repair.
- F.D.C.: obstructed / missing caps / needs repair / needs locking caps.

COMBUSTIBLE AND FLAMMABLE LIQUIDS

- Storage: location / required type / condition.
- Type of combustible violating fire code: liquid / compressed / cryogenic / L.P.G.
- Dikes: location / required / condition.
- Gas lines need to be tested. Date Tested: _____
- Pressurized cylinders not anchored.

Okay as of this date:

1st Warning

of Fire Code Violation:

2nd Warning

of Fire Code Violation:

VIOLATIONS / COMMENTS (All items that are circled and/or any that are listed below, must be corrected.):

RECOMMEND:

Such conditions are violations of either City or State Fire Prevention regulations. Please correct hazard(s) and help prevent fire. PROTECT LIFE AND PROPERTY.

Fire Marshal / Assistant Fire Marshal

Fire Chief

Fire Inspector & Call Sign

Occupant / Owner

Re-Inspection Date

Date:

If not corrected by this date, this matter will be processed through the Municipal Court.