



INVITATION TO BID

BID #2010-47 PURCHASE OF TWO (2) 4" PUMPS FOR LIFT STATION NO.19

The City of Edinburg, Texas is soliciting sealed separate bids for the above referenced as requested by the Utilities Department. The bid shall be received no later than **3:00 p.m., Monday, February 22, 2010.** Any bid received after the time set for opening will be returned to bidder unopened. Bidder(s) must provide an original and shall be addressed to:

CITY OF EDINBURG
C/O CITY SECRETARY
415 W. UNIVERSITY DRIVE
P.O. BOX 1079
EDINBURG, TEXAS 78540-1079

Bids must be submitted in an envelope sealed with tape and prominently marked on the lower left hand corner of the bid envelope with corresponding bid number and title. All bids will be opened and publicly read aloud at the above designated time at the City of Edinburg (New City Hall) Conference Room, 1st Floor, located at 415 W. University Drive, Edinburg, Texas. Bids sent via facsimile shall not be accepted.

The City of Edinburg reserves the right to accept or reject bids submitted, waive formalities in bidding, accept the bid deemed most advantageous to the City of Edinburg, and to hold the bids for a period of sixty (60) days without taking action thereon. If you have any questions or require additional information regarding this bid, please contact Mr. Agustin Gomez, Waste Water Treatment Plant Superintendent, at (956) 292-2042.

If you choose not to submit a bid and would like to remain on the City of Edinburg bidder's list for future bids, you must respond in writing.

Sincerely,


Lorena Fuentes, Purchasing Agent



415 W. University Drive • P.O. Box 1079 • Edinburg, Texas 78540
Phone (956) 388-8204 • Fax (956) 383-7111



INVITATION TO BID

ASSIGNED BID NO.: 2010-47

BID TITLE: Purchase of Two (2) 4" Pumps for Lift Station No. 19

CLOSED DATE & TIME: February 22, 2010 @ 3:00 PM SPECIFICATIONS ATTACHED XX

DELIVER SEALED BID TO: CITY OF EDINBURG ADDENDUM ONLY _____
C/O CITY SECRETARY
415 W. UNIVERSITY DRIVE
P.O. BOX 1079
EDINBURG, TEXAS 78540

Quotations are requested for furnishing materials or services described below in accordance with terms set forth herein.

ITEM	QUANTITY	DESCRIPTION OF GOODS OR SERVICES	UNIT PRICE	AMOUNT
1	2	Purchase of Two (2) 4" Pumps, 10 HP Motors for Lift Station No.19	\$ _____	\$ _____
		GRAND TOTAL		\$ _____
<p>Note: The City reserves the right to accept or reject bids submitted, waive formalities in bidding, consider each item submitted as a separate bid, award all or individually, whichever may be more advantageous to the City, and to hold the bids for a period of sixty (60) days without taking action thereon.</p>				

GENERAL CONDITIONS & INSTRUCTIONS – READ CAREFULLY

1. The bids must be submitted on this form only.
2. The City reserves the right to accept or reject any or all bids, waive formalities, and accept the bid deemed most advantageous to the City.
3. The City reserves the right to award the bid to the lowest responsible bidder.
4. Prices must be itemized.
5. All quotations must be F.O.B. Edinburg and include all costs for delivery and packaging.

Delivery time shall be specified by the bidder. Failure to state a firm delivery date will make an incomplete bid. Delivery time will be one of the determining factors in selecting the best bid. However, if the delivery time is not met when stated, upon notification of the same, the City may allow a ten-day grace period for delivery. If delivery is not met after the ten-day grace period allowed, the City of Edinburg reserves the right to completely cancel order and to revoke and render void the purchase order previously issued for same.

6. In cases of discrepancy between the unit price and the extension, the unit price will be taken.
7. All bids must be signed by an authorized representative.
8. Envelope containing this bid **must** be marked with **Bid No. and Bid Title** from Page 1 and sealed with tape.
9. Bid guarantee (if applicable) must be submitted with bid.
10. Any bid received after the time set for opening will be returned to bidder unopened.
11. This bid tabulation shall constitute a binding contract subject to acceptance by the City.
12. Special reference is made to bid specifications (if attached) for other conditions and instructions.
13. Failure to adhere or comply with the above general conditions and instructions will cause the bid to be rejected.
14. Bidders are advised that in addition to local bids received, the City participates in Texas Cooperatives that comply with the bidding requirements of the State of Texas; therefore, the City will include State Cooperative pricing to determine the selection of bid award that is most advantageous to the City.
15. No citizen or business shall be qualified to submit competitive bids for city purchases or improvements if it has a substantial delinquency to the City, including taxes, utility bills, or rental obligations, or has pending litigation against the City.

In compliance with the invitation for bid, and subject to all conditions thereof, the undersigned offers, and agrees, if this bid be accepted within 60 days from **time of closing**, to furnish any or all of the items or render such services upon which prices are quoted in accordance with the bid specifications applying, and at the price set opposite each item.

For bid inquiries, please call the Purchasing Agent at (956) 388-1895, Ext. 8972.

DATE: _____

BID PRICE: _____

DELIVERY DATE: _____

BIDDER NAME: _____

AUTHORIZED SIGNATURE: _____

TITLE: _____

MAILING ADDRESS: _____

TELEPHONE NO.: _____

E-MAIL ADDRESS: _____

FEDERAL ID #: _____

CITY OF EDINBURG
Wastewater Treatment Plant

Lift Station No. 19 Pump Replacement and Upgrade

SPECIFICATIONS

The bid specifications consist of the following items:

- 1) Purchase of two (2) new 4" Pumps, 10HP Motor, 535 GPM (gallons per minute) at 48.7 feet of Total Dynamic Head, 1735 rpm, 230 volt, 3 Phase, 60 HZ and 50 foot length of SUBCAB, 10 AWG, 3-2-1 GC Submersible cable, FLS leakage detector, a four (4) inch discharge to match existing pump base system or equal pump retrofitted to the existing pump base and guide rail system.
- 2) Pumps should be Flygt non-clog wastewater pumps, or approved equal.
- 3) Power cable shall be sized according to NEC and ICEA Standards and have P-MSHA approval.
- 4) Major pump components shall be cast iron, ASTM-48, Class 35B with smooth surfaces devoid of blow holes or other irregularities.
- 5) All exposed nuts or bolts shall be AISI type, 304 stainless steel construction.
- 6) All metal surfaces coming into contact with the pump, other than stainless steel or brass, shall be protected by a factory applied spray coating or acrylic dispersion zinc phosphate primer with polyester resin paint on the exterior of the pump.
- 7) The impeller shall be of ASTM-A-48, Class 35B gray iron or ASTM A-532 (Alloy III) 25% chrome cast iron, dynamically balanced, semi open, multi-vane, back swept, screw shape, and non-clog design.

David Salinas, Director of Utilities


