



## INVITATION TO BID

### BID #2010-66 PURCHASE OF FIRE HYDRANTS

The City of Edinburg, Texas is soliciting sealed separate bids for the above referenced as requested by the Utility Department. The bid shall be received no later than **3:00 p.m., Monday, May 10, 2010**. Any bid received after the time set for opening will be returned to bidder unopened. Bidder(s) must provide an original and shall be addressed to:

CITY OF EDINBURG  
C/O CITY SECRETARY  
415 W. UNIVERSITY DRIVE  
P.O. BOX 1079  
EDINBURG, TEXAS 78540-1079

**Bids must be submitted in an envelope sealed with tape and prominently marked on the lower left hand corner of the bid envelope with corresponding bid number and title.** All bids will be opened and publicly read aloud at the above designated time at the City of Edinburg (New City Hall) Conference Room, 1<sup>st</sup> Floor, located at 415 W. University Drive, Edinburg, Texas. Bids sent via facsimile shall not be accepted.

The City of Edinburg reserves the right to accept or reject bids submitted, waive formalities in bidding, accept the bid deemed most advantageous to the City of Edinburg, and to hold the bids for a period of sixty (60) days without taking action thereon. If you have any questions or require additional information regarding this bid, please contact Mr. Juan J. Flores, Systems Superintendent, at (956) 388-8212.

**If you choose not to submit a bid and would like to remain on the City of Edinburg bidder's list for future bids, you must respond in writing.**

Sincerely,

Lorena Fuentes, Purchasing Agent



# INVITATION TO BID

ASSIGNED BID NO.: 2010-66

BID TITLE: Purchase of Fire Hydrants

CLOSED DATE & TIME: May 10, 2010 @ 3:00 PM      SPECIFICATIONS ATTACHED XX

DELIVER SEALED BID TO: CITY OF EDINBURG      ADDENDUM ONLY \_\_\_\_\_  
C/O CITY SECRETARY  
415 W. UNIVERSITY DRIVE  
P.O. BOX 1079  
EDINBURG, TEXAS 78540

Quotations are requested for furnishing materials or services described below in accordance with terms set forth herein.

ITEM	QUANTITY	DESCRIPTION OF GOODS OR SERVICES	UNIT PRICE	AMOUNT
1	4	3' Fire Hydrant	\$ _____	\$ _____
2	8	4' Fire Hydrant	\$ _____	\$ _____
3	5	5' Fire Hydrant	\$ _____	\$ _____
4	3	3' Extensions	\$ _____	\$ _____
5	3	2' Extensions	\$ _____	\$ _____
6	3	1' Extensions	\$ _____	\$ _____
<b>GRAND TOTAL</b>				\$ _____
Delivery Time: _____				
The City reserves the right to increase or decrease quantities depending on availability of funds.				
Note: The City reserves the right to accept or reject bids submitted, waive formalities in bidding, consider each item submitted as a separate bid, award all or individually, whichever may be more advantageous to the City, and to hold the bids for a period of sixty (60) days without taking action thereon.				

## GENERAL CONDITIONS & INSTRUCTIONS – READ CAREFULLY

1. The bids must be submitted on this form only.
2. The City reserves the right to accept or reject any or all bids, waive formalities, and accept the bid deemed most advantageous to the City.
3. The City reserves the right to award the bid to the lowest responsible bidder.
4. Prices must be itemized.
5. All quotations must be F.O.B. Edinburg and include all costs for delivery and packaging.

Delivery time shall be specified by the bidder. Failure to state a firm delivery date will make an incomplete bid. Delivery time will be one of the determining factors in selecting the best bid. However, if the delivery time is not met when stated, upon notification of the same, the City may allow a ten-day grace period for delivery. If delivery is not met after the ten-day grace period allowed, the City of Edinburg reserves the right to completely cancel order and to revoke and render void the purchase order previously issued for same.

6. In cases of discrepancy between the unit price and the extension, the unit price will be taken.
7. All bids must be signed by an authorized representative.
8. Envelope containing this bid **must** be marked with **Bid No. and Bid Title** from Page 1 and sealed with tape.
9. Bid guarantee (if applicable) must be submitted with bid.
10. Any bid received after the time set for opening will be returned to bidder unopened.
11. This bid tabulation shall constitute a binding contract subject to acceptance by the City.
12. Special reference is made to bid specifications (if attached) for other conditions and instructions.
13. Failure to adhere or comply with the above general conditions and instructions will cause the bid to be rejected.
14. Bidders are advised that in addition to local bids received, the City participates in Texas Cooperatives that comply with the bidding requirements of the State of Texas; therefore, the City will include State Cooperative pricing to determine the selection of bid award that is most advantageous to the City.
15. No citizen or business shall be qualified to submit competitive bids for city purchases or improvements if it has a substantial delinquency to the City, including taxes, utility bills, or rental obligations, or has pending litigation against the City.
16. Unless otherwise specified, any catalog or manufacturer's reference or brand name used in describing an item is merely descriptive, and not restrictive, and is used only to indicate type and style of **FIRE HYDRANTS** desired. If a bidder quotes on equipment other than the one(s) specified in the bid and sufficient specifications and descriptive (pictured literature) data must accompany same to permit thorough evaluation. In the absence of these qualifications, he/she will be expected to furnish the **FIRE HYDRANTS** called for.

In compliance with the invitation for bid, and subject to all conditions thereof, the undersigned offers, and agrees, if this bid be accepted within 60 days from **time of closing**, to furnish any or all of the items or render such services upon which prices are quoted in accordance with the bid specifications applying, and at the price set opposite each item.

For bid inquiries, please call the Purchasing Agent at (956) 388-1895, Ext. 8972.

DATE: \_\_\_\_\_

BID PRICE: \_\_\_\_\_

DELIVERY DATE: \_\_\_\_\_

BIDDER NAME: \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

TITLE: \_\_\_\_\_

MAILING ADDRESS: \_\_\_\_\_

TELEPHONE NO.: \_\_\_\_\_

E-MAIL ADDRESS: \_\_\_\_\_

FEDERAL ID #: \_\_\_\_\_

## **FIRE HYDRANT SPECIFICATIONS**

Fire hydrants purchased or installed shall meet or exceed all applicable requirements and tests of ANSI and the latest revisions of AWWA Standard C502. Fire hydrants shall meet all test requirements and be listed by Underwriters Laboratories Inc. Fire hydrants shall meet all test requirements and have full approval of Factory Mutual. Fire hydrants shall meet the following requirements:

1. Fire hydrants shall be rated for a working pressure of 250 Psig.
2. Fire hydrants shall be of the compression type, opening against the pressure and closing with the pressure.
3. Fire hydrants shall have a minimum 5¼" main valve opening and a minimum inside lower/upper barrel diameter (I.D.) of 7" to assure maximum flow performance. Pressure loss at 1,000 GPM shall not exceed the following values: 4" Pumper Nozzle —2.70 psi, 4.5" Pumper Nozzle —2.50 psi.
4. Fire hydrants shall be three-way in design, having one (1) 4 ½" pumper nozzle and two 2 ½" hose nozzle(s). Nozzle thread type shall be National Standard Thread. Nozzles shall thread counterclockwise into hydrant barrel utilizing "o" ring seals. A suitable nozzle lock shall be in place to prevent inadvertent nozzle removal.
5. The bonnet assembly shall provide an oil reservoir and lubrication system that automatically circulates lubricant to all stem threads and bearing surfaces each time the hydrant is operated. This lubrication system shall be sealed from the waterway and any external contaminants by use of "o" ring seals. An anti-friction washer shall be in place above the thrust collar to further minimize operating torque. The oil reservoir shall be factory filled with a low viscosity; FDA approved non-toxic oil lubricant which will remain fluid through a temperature range of -60° F to +150° F.
6. The operating nut shall be a one piece design, manufactured of ASTM B-584 bronze. It shall be pentagon/square in shape and the nut dimensions shall be 1 ½". The operating nut shall be affixed to the bonnet by means of an ASTM B-S 84 bronze hold down nut. The hold down nut shall be threaded into the bonnet in such a manner as to prevent accidental disengagement during the opening cycle of the hydrant. The use of Allen head set screws as a means of retention is unacceptable. A resilient weather seal shall be incorporated into the hold down nut, for the purpose of protecting the operating mechanism from the elements.
7. The direction of the opening shall be a word open and an arrow shall be cast on the bonnet flange to indicate the specified opening direction.

8. The hydrant bonnet shall be attached to the upper barrel by not less than eight bolts and nuts and sealed by an "o" ring.
9. Hydrants shall be a "traffic-model" having upper and lower barrels joined at the ground line by a separate and breakable "swivel" flange providing 360 degree of rotation of upper barrel for proper nozzle facing. This flange shall employ not less than eight bolts. The safety flange segments shall be located under the upper barrel flange to prevent the segments from falling into the lower barrel when the hydrant is struck. The pressure seal between the barrels shall be an "o" ring. The proper ground line shall be cast clearly on the lower barrel and shall provide not less than 18" of clearance from the centerline of the lowest nozzle to the ground.
10. The operating stem shall consist of two pieces, not less than 1¼" diameter (excluding threaded or machined areas) and shall be connected by a stainless steel safety coupling. The safety coupling shall have an integral internal stop to prevent the coupling from sliding down into the lower barrel when the hydrant is struck. Screws, pins, bolts, or fasteners used in conjunction with the stem couplings shall also be stainless steel. The top of the lower stem shall be recessed 2" below the face of the safety flange to prevent water hammer in the event of a "drive over" where a vehicle tire might accidentally depress the main valve.
11. The lower barrel shall be an integrally cast unit. The use of threaded on or mechanically attached flanges is deemed unacceptable. The hydrant bury depth shall be clearly marked on the hydrant lower barrel.
12. Composition of the main valve shall be a molded rubber having a durometer hardness of 95 +/- 5 and shall be reversible in design to provide a spare in place. Plastic (polyurethane) main valves are unacceptable. The main valve shall have a cross section not less than 1".
13. Hydrants shall be equipped with two (2) drain valves which drain the barrel when the hydrant is closed and seal shut when the hydrant is opened. These drain valves shall be an integral part of the one piece bronze upper valve plate. They shall operate without the use of springs, toggles, tubes, levers or other intricate synchronizing mechanisms.
14. The upper valve plate, seat ring and drain ring (shoe bushing) must be ASTM B-584 bronze and work in conjunction to form an all bronze drain way. A minimum of two (2) internal and two (2) external drain openings are required. Drains ported through an iron shoe must be bronze lined.
15. The bronze seat ring shall thread into a bronze drain ring (or shoe bushing) providing a bronze-to-bronze connection. Seal rings shall be "o" ring pressure sealed.

16. The shoe inlet size and connection type shall be as specified (flanged, MJ, etc.) having ample blocking pads for sturdy setting and the MJ connection must have two strapping lugs to secure the hydrant to piping. A minimum of six bolts and nuts is required to fasten the shoe to the lower barrel.
17. The interior of the shoe including the lower valve plate and stem cap nut shall have a protective coating that meets the requirements of AWWA C-550. If a stem cap nut is utilized, it must be locked in place by a stainless steel lock washer or similar non-corrosive device that will prevent the cap nut from backing-off during normal use.
18. Hydrants shall be warranted by the manufacturer against defects in materials or workmanship for a period of ten (10) years from the date of manufacture. The manufacturing facility for the hydrant must have current ISO certification.
19. Hydrants shall be Mueller Super Centurion 250 or approved equal.

**Failure to comply with any of these above requirements is sufficient cause for rejection of proposed hydrants. The City of Edinburg reserves the right to accept only those materials that are in full compliance with these specifications and deemed most advantageous to the City.**