



ADDENDUM NUMBER ONE (1)

DATE: May 21, 2010

RE: BID NO. 2010-69 – West Side Drainage Improvements – Phase I
Sugar Rd. to Jackson Rd.

OWNER: CITY OF EDINBURG

TO: ALL PROPOSERS, HOLDERS OF SPECIFICATIONS, AND ALL INTERESTED
PARTIES TO THE CITY OF EDINBURG

BID OPEN: 3:00 P.M. (Central Time), Monday, May 24, 2010

The following clarifications, corrections and directives shall become part of the Proposal, Contract Documents and Specifications for **BID NO. 2010-69 – West Side Drainage Improvements – Phase I**.

PLANS

1. Sheet 2 of 5, Revise Note 6, to allow backfill PI to be greater than 20.
2. Sheet 5 of 5, Revise Detail Note "C" "Standard Pipe Bedding", to allow backfill PI to be greater than 20.

CLARIFICATIONS:

1. Volume of backfill was not estimated. Planametric CAD file is available for your information, by Contacting City of Edinburg, Engineering Department (956)388-8211. Contractor shall be responsible for determining necessary fill.
2. Borrow material will be made available from adjacent property. Excavation must be in accordance with directions from City Engineer.
3. Contractor shall be responsible for the relocation of approximately 165 L.F. of fence to the Right-of-way line. The cost of which shall be subsidiary to all the items of the Bid.
4. Page E-2, Revise "Special Provisions" Note 13, to allow work outside of the regular business hours, nights and weekends, with no additional cost to the contractor for the City's Field Inspector. All work hours must be requested & approved by City.
5. Access to the site way be made via Sugar Rd. provided that appropriate traffic control devices are installed & maintained by contractor at no additional cost to the owner.
6. All existing drain lines to be re-connected must be field verified for size by contractor.




210 W. McIntyre • P.O. Box 1079 • Edinburg, Texas 78540
Phone (956) 383-5661 • Fax (956) 383-7111




Please make the necessary corrections to the Plans and Proposal, as appropriate.

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE BID PROPOSAL FORM.


Approved by:



Isael Posadas, P.E., C.F.M.
Edinburg City Engineer



Please direct your questions regarding the preparation of the bid to Mr. Isael Posadas, P.E., C.F.M. at (956) 388-8211.



Lorena Fuentes, Purchasing Agent