

**EDINBURG DOWNTOWN WTP FILTER UNDERDRAIN UPGRADE
BID # 2013-66**

**CITY OF EDINBURG
EDINBURG, TEXAS**

**BID OPENING DATE: MONDAY, APRIL 8, 2013
BID OPENING TIME: 3:00 P.M.**

**ADDENDUM NUMBER TWO (2)
MARCH 27, 2013**

Notice to All Bidders and Parties of Interest the following changes have been made:


1. Page C-5 of the Bid Proposal - the number of calendar days to complete project will be **270 calendar days**.
2. Bird control devices will not be installed in the project, Section 10813 is removed from specifications.
3. A total of **Five (5)** filters are being upgraded - Filter No. 3 in Old Section and Filters 6, 7, 8, and 9 in the Middle Section. Middle Section will be equipped with Air Scour.
4. Pipe discharge on Plan Sheet 12 will be **8-inch** diameter.
5. Note 1 on Plan Sheets 5 through 8 and 10 will read as follows:
Install two (2) 1280 SCFM @ 6.0 psi positive displacement blowers in acoustical enclosure, Universal Blower Pac, Inc. Attenu-Pac Blower Package utilizing a 480V, 45 HP NEMA Frame Motor.
6. Technical specification Section 46111 - Part 1.01B-3 Related Sections are replaced as follows:
 - c. Section 03600 - Grouting replaced with Section 03072 Epoxy Resin / Portland Cement Bonding Agent
 - d. Section 05500 - Metal Fabrication replaced with Section 05500 - Miscellaneous Metal
 - e. Section 07900 - Joint Sealant replaced with Section 03071 - Epoxies
7. Old Section **Filter Number 3** will have existing troughs removed and replaced with new concrete troughs.
8. **Electrical submittal** will be required for the Air Compressor installation with sealed plans from Engineer prior to installation.
9. A sealed Safety Railing shop drawing layout will be required prior to fabrication and installation of safety railing.
10. A sealed Compressed Air Piping shop drawing layout will be

required prior to fabrication and installation of air scour system.

11. The Bid Opening has been extended to Monday, April 8, 2013 at 3:00 P.M.
12. Liquidated damages will be assessed at \$200.00 per day.
13. Attached herewith is the Pre-Bid Conference Sign-In Sheet.
14. Pre-Bid conference is not mandatory.

All other conditions and requirements in the Notice to Bidders, Instructions to Bidders, Specifications, Geotechnical Engineering Study, and Plans remain unchanged. If you have any questions or remarks please notify the office of R. Gutierrez Engineering Corporation at 956-782-2557 or at art@rgec.net in written form.

R. GUTIERREZ ENGINEERING CORPORATION
T.B.P.E. FIRM: F-486

 3-27-13
Arturo Garcia, Jr., P.E. Date



END OF ADDENDUM NUMBER TWO (2)

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED BELOW AND E-MAIL BACK TO MS. LORENA FUENTES, PURCHASING AGENT, AT THE FOLLOWING E-MAIL: lfuentes@cityofedinburg.com. PLEASE INCLUDE THIS FORM IN YOUR BID PROPOSAL.

NAME: _____ **TITLE:** _____

COMPANY NAME: _____

PLEASE DIRECT YOUR QUESTIONS REGARDING THE PREPARATION OF THE BID TO MR. PONCIANO N. LONGORIA, P.E., DIRECTOR OF PUBLIC WORKS, AT 956-388-8211 AND/OR MS. LORENA FUENTES, PURCHASING AGENT, AT 956-388-8972.