

**DOCUMENT 00 91 13-3**  
**ADDENDA**  
**ADDENDUM NUMBER THREE**



DATE: November 11, 2013

PROJECT: City of Edinburg Safe Room – South Park Site

PROJECT NUMBER: 1204

11/11/2013

OWNER: City of Edinburg

ARCHITECT: Negrete & Kolar Architects, LLP

TO: Prospective Bidders

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated October 15, 2013, Addendum Number one issued November 5, 2013, with amendments and additions noted below.

Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder.

This Addendum consists of ONE pag:

No.	Drawing Title	Issue Date

CHANGES TO ADDENDUM NUMBER ONE Issued November 5, 2013.

1. Under changes to the project manual, changes to the Notice to Bidders, item 1.c, change the time for the second pre-bid meeting to be: "3:00 pm"

CLARIFICATIONS TO THE DRAWINGS

1. Question posed: Are there any pour joints required for the foundation or slab?  
Answer: The structural drawings do not require a pour joint nor impose a maximum area of pour. It is up to the Contractor and their means and methods as to whether the Contractor may require a cold pour joint.

**END OF DOCUMENT**