

December 19, 2013

130-2167

All Bid Holders of Record

**RE: CITY OF EDINBURG
BID NUMBER 2014-40
CELL 5A CELL CONSTRUCTION, EDINBURG SANITARY LANDFILL
ADDENDUM NO. 3**

Dear Recipient:

Golder Associates Inc (Golder), has prepared this Addendum No. 3 to the above-mentioned bid documents. This addendum forms a part of the bid documents and modifies the original "Invitation to Bid" dated December 2013.

Bidders must acknowledge receipt of this addendum in the space provided on the Bid Form, Item C on Page 00003-2 and 00003-7. Failure to do so may result in disqualification.

Addendum No. 2 consists of the clarification provided below.

1.0 SPECIFICATION 02822 - FENCING

Part I, Section 1.1.A.1 of Specification 02822 – Fencing has been revised to read "Ten (10) foot Deer Fence". The section is also revised to remove Part 3 – Execution.

The revised Specification is attached to this addendum.

Note that the Contractor is only supplying the required fencing materials.

Sincerely,

GOLDER ASSOCIATES INC.



Mark E. Roth
Associate



William E. Gordon, P.E.
Senior Engineer



Attachments:

Section 02822 Revised – Fencing

cc: Ramiro L. Gomez, Jr., City of Edinburg

MERWEG/weg

SECTION 02822 Revised– FENCING

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes
 - 1. Ten (10) foot Deer Fence

1.2 REFERENCES

- A. None

1.3 SUBMITTALS

- A. None.

1.4 QUALITY ASSURANCE

- A. Fencing material, posts, and components, and installation shall conform to the requirements of this Section unless otherwise shown or specified.
- B. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this Section with minimum 3 years documented experience.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Steel Posts: 2 ¾ inch steel drill pipe approximately 16 feet in length.
- B. Wooden Posts: 6 inch diameter treated wood approximately 16 feet in length.
- C. Fencing: Class 3 galvanized; 9 Gauge inside and bottom wire; 6 Gauge top wire; 12” stay opening; 9 horizontal wires.
- D. End, Corner, and Pull Posts: 6 inch diameter treated wood approximately 16 feet in length.
- E. Line (Intermediate) Posts: 2 ¾ inch steel drill pipe approximately 16 feet in length.
- F. Wire Ties: Class 1 galvanized steel, no less than 9 gauge.
- G. Ready Mix Concrete: ASTM C94, mix design as follows:
 - 1. Design mix to produce normal weight concrete consisting of Portland cement, aggregate, water-reducing admixture, air-entraining admixture, and water to produce following:
 - a. Compressive Strength: 3,500 psi, minimum at 28 days, unless otherwise indicated on Construction Drawings.

- b. Slump Range: 1 to 3 inches at time of placement
- c. Air Entrainment: 5 to 8 percent

H. Water: Clean

END OF SECTION 02822 - Revised