

ADDENDUM NUMBER ONE (1)

DATE: October 1, 2014

RE: BID NO. 2015-01 – MINOR REHABILITATION OF SOUTHWEST ELEVATED STORAGE TANK

OWNER: CITY OF EDINBURG

TO: ALL PROPOSERS, HOLDERS OF SPECIFICATIONS, AND ALL INTERESTED PARTIES TO THE CITY OF EDINBURG

BID OPEN: 3:00 P.M. (Central Time), October 6, 2014

The following corrections and directives shall become part of the Proposal, Contract Documents and Specifications for **BID No. 2015-01– MINOR REHABILITATION OF SOUTHWEST ELEVATED STORAGE TANK**

PLANS & SPECIFICATIONS


1. Clarification: Section 4, Bid Proposal, bid item 4 shall be amended by adding the following after TANK, **“AND REPAIR STANDOFF ON OVERFLOW PIPE SUPPORT BY WELDING A PIECE OF CARBON STEEL SAME THICKNESS AS EXISTING AND REPAINTING PER SPECIFICATIONS”**
2. Clarification Plan sheet 2: The following picture shall be added as plan sheet 2. Picture 1 is to show bidder the standoff repair which is subsidiary to bid item 4. Picture 2 depicts the amount of corrosion on existing condensate platforms. Typical of 2 platforms. This is subsidiary to bid item 4.
3. Clarification Plan sheet 2: The following picture is to show additional corrosion on the top of the tank to be repaired with bid item 2

Please make the necessary corrections to the Plans and Proposal, as appropriate.



415 W. University Drive • P.O. Box 1079 • Edinburg, Texas 78540
Phone (956) 388-8204 • Fax (956) 383-7111





W 93° 11' 23.03"
N 26° 15' 40.20"

9/10/2014 11:35:58 AM

PICTURE 1.



PICTURE 2.



PICTURE 3.

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE BID PROPOSAL FORM.

Approved by:


Philip W. Huseman, P.E.
Project Manager

Please direct your questions regarding the preparation of the bid to Mr. Philip Huseman, PE. 281-494-3252


Lorena Fuentes, Purchasing Agent