



**BID REQUEST
ADDENDUM NUMBER ONE (1)**

DATE: February 6, 2020
RE: BID NO. 2020-29 – POLYMER SUPPLY
OWNER: CITY OF EDINBURG
TO: ALL PROPOSERS, HOLDERS OF SPECIFICATIONS, AND ALL
ALL INTERESTED PARTIES TO THE CITY OF EDINBURG

All Addenda issued in respect to this project shall be considered official changes to the original bid documents and shall become a part of the contract documents.

SPECIFICATIONS ADDENDUM ITEM AS SPECIFIED BELOW:

CLARIFLOC C-6266 PWG POLYMER CHARACTERISTICS, OR APPROVED EQUAL:

Products supplied MUST be approved and registered with the ENVIRONMENTAL PROTECTION AGENCY (EPA); be acceptable to the TEXAS COMMISSION ON ENVIRONMENTAL QUALITY (TCEQ) and conform to American National Standards Institute/National Sanitation Foundation (ANSI/NSF) for use with potable water.

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED BELOW AND RETURN TO MS. LORENA FUENTES, PURCHASING AGENT VIA EMAIL AT fuentes@cityofedinburg.com. PLEASE INCLUDE THIS FORM IN YOUR BID PROPOSAL.

NAME: *John Mestas* TITLE: *2/6/2020*
COMPANY: *CITY OF Edinburg*

If you have any questions or require additional information, do not hesitate to contact Ms. Lorena Fuentes, Purchasing Agent at (956) 388-1895.

Lorena Fuentes
Lorena Fuentes, Purchasing Agent



City of Edinburg Water Treatment Plant (1752 S. Mon Mack Rd.)
Specification – Belt Filter Press Polymer

1. Estimated quantities based on projected usage during a twelve (12) month period. The City will be ordering approximately four drums on an as needed basis. The City may increase or decrease the usage depending on availability of funds.
2. The unit prices for this contract shall remain the same, whether the City buys more or less than the amount of the product, and will not increase or decrease more than 25% without the consent of the vendor.
3. The price quoted shall prevail for a contract period of twelve (12) months, or as otherwise specified from the time of acceptance and issuance of the Purchase Order.
4. Bid price shall include any freight charges, deposits, rent, and demurrage charges for containers, if any. The City will not be responsible for any additional costs not included in the bid price.
5. The unit price per 55 gallon drums shall be specified by the bidder.
6. Superfund tax, hazardous handling charge, fuel surcharge, or other environmental charge shall be included in the bid price, or specified as an addendum. The City will not be responsible for any additional costs not included in the bid price.
7. Vendor must conduct three (3) polymer integrity evaluation analyses during the fiscal year.
8. **Product supplied MUST be approved and registered with the ENVIRONMENTAL PROTECTION AGENCY (EPA); be acceptable to the TEXAS COMMISSION ON ENVIRONMENTAL QUALITY (TCEQ) and conform to American National Standards Institute/National Sanitation Foundation (ANSI/NSF) for use with potable water.**
9. The polymer will have the CLARIFLOC C-6266 PWG Polymer characteristics, or an approved equal:
 - a. Appearance – Milky
 - b. Ionic Character – Cationic
 - c. Charge Density – very high
 - d. Molecular Weight – very high
 - e. Approximate Bulk Density – 1.04
 - f. Average Non-Volatile Solids (%) – 47
 - g. Recommended working concentration (g/l) – 10
 - h. Bulk Viscosity – (cps) – 1200
 - i. Stability of D.I. Solution (days) – 1
 - j. Dilution to Obtain 5 g/l Active Content – 92
 - k. Approximate viscosity @ 5 g/l Active Content (cps) – 1600
 - l. Storage Temperature (Degree C) – 0-35
 - m. Shelf Life (months) – 6