



REQUEST FOR PROPOSAL
ADDENDUM NUMBER ONE (1)

DATE: NOVEMBER 14, 2018
RE: RFP #2019-08 – CITY OF EDINBURG SOUTH EAST ORIGINAL TOWNSITE DRAINAGE IMPROVEMENTS
OWNER: CITY OF EDINBURG
TO: HOLDERS OF RFP, AND ALL INTERESTED PARTIES TO THE CITY OF EDINBURG

The following changes shall become part of the Request for Proposals for **RFP #2019-08-CITY OF EDINBURG SOUTH EAST ORIGINAL TOWNSITE DRAINAGE IMPROVEMENTS**

SPECIFICATIONS ADDENDUM ITEM AS SPECIFIED BELOW:

CLARIFICATIONS/MODIFICATIONS

1. DRAINAGE MANHOLE COVER AND RINGS SIZE SHALL BE 32" AS PER CITY OF EDINBURG SPECIFICATIONS. (SEE ATTACHED EXHIBIT A)

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED BELOW AND RETURN TO MS. LORENA FUENTES, PURCHASING AGENT VIA EMAIL TO lfuentes@cityofedinburg.com. PLEASE INCLUDE THIS FORM IN YOUR PROPOSAL.



NAME: _____ TITLE: _____

COMPANY: _____


If you have any questions or require additional information, do not hesitate to contact Ms. Lorena Fuentes, Purchasing Agent at (956) 388-1895.



Lorena Fuentes, Purchasing Agent



COVER SECTION



FRAME SECTION

**CITY STANDARD ROADWAY MANHOLE
RING AND COVER CASTING DETAIL**



THE SEAL APPEARING ON THIS DOCUMENT WAS AUTHORIZED BY ISRAEL POSADAS, P.E. No. 89435 ON NOVEMBER 14, 2018. ALTERATION OF A SEALED DOCUMENT WITHOUT PROPER NOTIFICATION OF THE RESPONSIBLE ENGINEER IS AN OFFENSE UNDER THE TEXAS ENGINEERING PRACTICE ACT.

SDI ENGINEERING, LLC

CIVIL • TRANSPORTATION • PLANNING • STORMWATER

5602 E. IOWA RD., EDINBURG, TEXAS (956) 287-1818 PH. (956) 287-3697 FAX

INFO@SDI-ENGINEERING.COM

TBPE REG. NO. F-13016